



# Collier County Housing Authority

April 7, 2021

To: All Bidders

**Subject: ITB2021-02 Amendment #1**

This Notice compromises Amendment #1 to the subject Invitation to Bid (ITB) for heating, ventilation, and air Conditioning Services (HVAC) Services.

The amendment corrects the Condenser unit used for the 2 bedroom (Duplexes).

In reviewing the information, it was confirmed that the unit used is a 2 Zone unit and CCHA requires a 3 or 4 zone unit.

The model # used is 38MGRQ18B—3, which is the same unit used for the 1-bedroom (2 zone) units.

The "CCHA" required model # would be need is: **38MGRQ30D—3**, this is a 4-zone unit, used in the 3-bedroom units.

Changes should be in plans M-2 and M-5.

Sincerely,

A handwritten signature in blue ink, appearing to read "Oscar Hentschel".

Oscar Hentschel  
Executive Director  
Collier County  
Housing Authority  
239-657-3649  
[www.cchaf.org](http://www.cchaf.org)